


Dexter Community Schools 2009 Electrical and Natural Gas Usage Building Use per Square Foot



Building	Use	Prorated Area	Use/ft ²
Transportation Dept.	90,640.000 KWH	7170	12.642
Wylie Elementary (Cornerstone, Mill Creek)	3,276,350.000 KWH	283727	11.548
Dexter High School	2,698,880.000 KWH	300656	8.977
Bates Elementary	312,000.000 KWH	37393	8.344
Copeland	177,900.000 KWH	22040	8.072
Creekside Intermediate	882,313.000 KWH	90204	7.237
Bates Portable Classroom Bldgs.	27,920.000 KWH	4800	5.817
Proctor House	8,148.000 KWH	4550	1.791
Proctor House	3,671.000 CCF	4550	0.807
Wylie Elementary	63,119.000 CCF	108792	0.580
Bates Elementary	21,321.000 CCF	37393	0.570
Mill Creek Middle	59,159.000 CCF	111600	0.530
Copeland	11,222.000 CCF	22040	0.509
Dexter High School	148,554.000 CCF	300656	0.494
Transportation Dept.	3,509.000 CCF	7170	0.489
Cornerstone Elementary	29,092.000 CCF	63335	0.459
Creekside Intermediate	50,241.000 CCF	120271	0.418